

SUPPLY AIR FILTER AND RETURN AIR DUCT SMOKE DETECTION SYSTEM

NOTES:

1. FOR LEGEND, ABBREVIATIONS & GENERAL NOTES, SEE DWG. E-1.
2. REMOVE TRX AND E.O.L. FROM EXIST. BOX LOCATED ABOVE MCC AND INSTALL TRX-88 AND NEW E.O.L. DISCONNECTION AND RECONNECTION OF PURGE SWITCH CIRCUITRY SHALL BE DONE BY THE CONTRACTOR IN THE PRESENCE OF THE ENGINEER.
3. FOR 41st FLOOR MER PLAN, SEE DWG. E-31.
4. FOR 41st FLOOR MER REMOVAL PLAN, SEE DWG. E-32.

Sheet 32 of 39

**THE PORT AUTHORITY
OF NY & NJ**

**Engineering Program Manager
WORLD TRADE
CENTER**

No. Date Revision Approved

**Engineering Department
Design Division
The World Trade
Center**

**FIRE ALARM SYSTEM
PHASE III
XL3 CONVERSION
ELECTRICAL
2 WTC
41st FLOOR MER
FIRE ALARM SYSTEM
RISER DIAGRAM**

This drawing is subject to conditions in contract. All inventions, ideas, designs and methods herein are reserved to Port Authority and may not be used without its written consent.

**ROYZMAN
FELDSTEIN**
Designed by

ROYZMAN
Drawn by

A.S.
Checked by

Date 5-26-99 Scale NONE
Contract Number Drawing Number
WTC-861082 E-30

I HEREBY CERTIFY THAT THIS IS A TRUE AND CORRECT COPY OF ONE OF THE CONTRACT DRAWINGS CONSTITUTING A PART OF CONTRACT NO. WTC 861 082 IN THE FORM IN WHICH SAID DRAWINGS EXISTED AT THE TIME THE SAID CONTRACT WAS EXECUTED BY THE PARTIES.

DATE 2/1/00 CONTRACT ENGINEER

DATE 2/1/00 ENGINEERING PROGRAM MGR

